



مدينة زويل للعلوم والتكنولوجيا
أعمال تنفيذ مبنى الجامعة (B8)

طلب اعتماد مواد

المالك: مدينة زويل للعلوم والتكنولوجيا	الاستشاري: المهندس/ المهندس الاستشاري Cgman
مقدم من: شركة أبناء مصر للتعمير (علام تكنولوجي)	موجه إلى: الهيئة الهندسية للقوات المسلحة (ط4)
اسم وتوقيع المرسل:	اسم وتوقيع المهندس الاستشاري:
بتاريخ: 29/12/2016	بتاريخ: 20/12/16

إصدار رقم: 00

رقم النموذج: MAT/B8/HVAC/0027

عنوان النموذج / Galvanized Sheet Metal		مستندات التعاقد	بديل	مستند	مستند	مستند
مستند	عدد النسخ	البيان / الوصف	المصنع / بلد الصنع	رمز المواصفات	رمز المقايسة	مستند
1	3	Galvanized Sheet Metal (HVAC) 1 Sample	Expert	15815		

تعهد المقاول: المستندات المرفقة تم تنسيقها ومراجعتها من حيث تطابقها مع العقد وتعتبر مقبولة للاستخدام في هذا المشروع من قبل المقاول

الملاحظات

مرضا الرد

ج = معتمد مع ملاحظات ويعاد التقديم مرة أخرى

أ = معتمد

د = الطلب مرفوض ويعاد التقديم مرة أخرى

ب = معتمد مع ملاحظات. يمكن للعمل أن يستمر بناء على الملاحظات

اعتماد استشاري الهيئة اعتماد طاقم الاشراف	م/م م/م	بتاريخ 2007/1/14
استلام المقاول	الاستلام بواسطة	بتاريخ 200 / /

التوزيع قبل الاعتماد : التوزيع بعد الاعتماد

No.	المالك	الاستشاري	المالك	المقاول	الاستشاري		
					مدني	معماري	كهرباء
					تخطيط	ميكانيكا	تكييف
					Q.S		

Faint handwritten notes at the top of the page.

Faint handwritten notes on the left side of the page.

Faint rectangular stamp or box in the lower-left quadrant.

Handwritten red text: "فردی و انفرادی" with arrows pointing to the 'S.R. Elec.' and 'S.R. Mech.' rows in the table below.

HASSAN ALLAM TECHNOLOGIES	
INFO	Address
	H.O
	P.M
	S.M
	C.M Elec.
	C.M Mech.
	S.R Elec.
	S.R Mech.
	Coordination
	Procurement
	Planning
	HSE
	S.Keeper
	H.R

B8 – University Complex

Technical Comments on Material No. MAT/HAT/B8/HVAC/0027

Comments on Galvanized duct work (Expert):-

Duct manufacturer is approved technically subject to:

- 1- Provide certified lab test for the used duct work from independent lab, similar to other buildings.
- 2- Provide which standards are followed for duct fabrication.
- 3- Provide duct construction details which will be followed in the building.
- 4- Provide submittal with type of gasket used for duct works.

The above shall be complied before any work proceed.

Consultant's action: (B) Approved as Noted



The Experience at ... Expert



Expert Middle East co.